



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE

13901 Crown Court, Woodbridge, Virginia 22193

(703) 583-3800 Fax (703) 583-3821

www.deq.virginia.gov

Douglas W. Domenech
Secretary of Natural Resources

David K. Paylor
Director

Thomas A. Faha
Regional Director

January 29, 2010

Mr. Darrell McClain, Engineer & Maintenance Director
Klockner Pentaplast
3585 Klockner Road
Gordonsville, VA 22942

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Re: Issuance VPDES Permit No. VA0092533
Klockner Pentaplast of America, Gordonsville/Louisa County

Dear Mr. McClain:

The Department of Environmental Quality (DEQ) has approved the enclosed effluent limitations and monitoring requirements for the above-referenced permit. A copy of your permit and the Discharge Monitoring Report (DMR) form is included. Please make additional copies of the DMR for future use. The first DMR for the second quarter is due by July 10, 2010. Please send DMRs to:

Virginia Department of Environmental Quality
Northern Regional Office
13901 Crown Court
Woodbridge, VA 22193-1453

Please reference the effluent limits in your permit and report monitoring results on the DMRs to the same number of significant digits as are included in the permit limits for the parameter.

Also note that the facility has a four year compliance schedule for copper and zinc parameters. You will be required to monitor only and report results on the DMR during the compliance schedule. A revised DMR will be issued to include final copper and zinc effluent limits upon completion of the compliance schedule.

DEQ has launched an e-DMR program that allows you to submit effluent data electronically. We expect every permittee to use e-DMR as permits are issued/reissued and exceptions will only be allowed on a case by case basis. There are many benefits to both DEQ and the permittee when e-DMR is utilized for submissions:

- 1) Fewer revisions for data since the e-DMR program automatically flags omissions before the data is submitted;
- 2) Cost savings on postage, copying, and paper;
- 3) No concerns about using the most current DMR – e-DMR refreshes the required parameters automatically when changes are needed;
- 4) Submittals can be made on a timelier basis; and
- 5) Electronic signatures from multiple people are allowed and e-DMR can be accessed from multiple computer locations.

The following website provides details <http://www.deq.virginia.gov/water/edmrfaq.html> and our regional e-DMR administrator, Becky Vice at rebecca.vice@deq.virginia.gov or (703)583-3922 can also assist you.

As provided by Rule 2A:2 of the Supreme Court of Virginia, you have thirty days from the date of service (the date you actually received this decision or the date it was mailed to you, whichever occurred first) within which to appeal this decision by filing a notice of appeal in accordance with the Rules of the Supreme Court of Virginia with the Director, Department of Environmental Quality. In the event that this decision is served on you by mail, three days are added to that period.

Alternately, any owner under §§ 62.1-44.16, 62.1-44.17, and 62.1-44.19 of the State Water Control Law aggrieved by any action of the State Water Control Board taken without a formal hearing, or by inaction of the Board, may demand in writing a formal hearing of such owner's grievance, provided a petition requesting such hearing is filed with the Board. Said petition must meet the requirements set forth in §1.23(b) of the Board's Procedural Rule No. 1. In cases involving actions of the Board, such petition must be filed within thirty days after notice of such action is mailed to such owner by certified mail.

If you have questions about the permit, please contact Susan Oakes at (703)583-3863, or by E-mail at susan.oakes@deq.virginia.gov.

Sincerely,



Bryant Thomas
Water Permits Manager

Enc.: Permit No. VA0092533

cc: James Gibson, Maintenance Manager
DEQ-Water, OWPP
EPA-Region III, 3WP12
Department of Health, Culpeper
Water Compliance, NRO

PERMITTEE NAME/ADDRESS(INCLUDE
FACILITY NAME/LOCATION IF DIFFERENT)

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM(NPDES)
DISCHARGE MONITORING REPORT(DMR)

Industrial Minor 01/21/2010

DEPT. OF ENVIRONMENTAL QUALITY
(REGIONAL OFFICE)

NAME Klockner Pentaplast of America 3585 Klockner Rd
ADDRESS PO Box 500
Gordonsville VA 22942
FACILITY LOCATION 3585 Klockner Rd

VA0092533				001			
PERMIT NUMBER				DISCHARGE NUMBER			
MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	

Northern Regional Office
13901 Crown Court

Woodbridge VA 22193

NOTE: **READ PERMIT AND GENERAL INSTRUCTIONS
BEFORE COMPLETING THIS FORM.**

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
001 FLOW	REPORTD				*****	*****	*****				
	REQRMNT	NL	0.0058	MGD	*****	*****	*****			1 / 3M	EST
002 PH	REPORTD	*****	*****			*****					
	REQRMNT	*****	*****		6.0	*****	9.0	SU		1 / 3M	GRAB
012 PHOSPHORUS, TOTAL (AS P)	REPORTD	*****	*****			*****					
	REQRMNT	*****	*****		NA	*****	NL	MG/L		1 / 3M	GRAB
080 TEMPERATURE, WATER (DEG. C)	REPORTD	*****	*****			*****					
	REQRMNT	*****	*****		NA	*****	32	C		1 / 3M	IS
137 HARDNESS, TOTAL (AS CACO3)	REPORTD	*****	*****			*****					
	REQRMNT	*****	*****		NA	*****	NL	MG/L		1 / 3M	GRAB
196 ZINC, TOTAL RECOVERABLE	REPORTD	*****	*****			*****					
	REQRMNT	*****	*****		NA	*****	NL	UG/L		1 / 3M	GRAB
203 COPPER, TOTAL RECOVERABLE	REPORTD	*****	*****			*****					
	REQRMNT	*****	*****		NA	*****	NL	UG/L		1 / 3M	GRAB
	REPORTD										
	REQRMNT									*****	

ADDITIONAL PERMIT REQUIREMENTS OR COMMENTS

BYPASSES AND OVERFLOWS	TOTAL OCCURRENCES	TOTAL FLOW(M.G.)	TOTAL BOD5(K.G.)	OPERATOR IN RESPONSIBLE CHARGE			DATE		
I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS TO THE BEST OF MY KNOWLEDGE AND BELIEF TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.				TYPED OR PRINTED NAME	SIGNATURE	CERTIFICATE NO.	YEAR	MO.	DAY
				PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE			
				TYPED OR PRINTED NAME	SIGNATURE		YEAR	MO.	DAY

This report is required by your VPDES permit and by law. (See, e.g., the Code of Virginia of 1950 §62.1-44.5 and 9 VAC 25-31-50.) Failure to report or failure to report truthfully can result in civil penalties of \$32,500 per violation, per day and felony prosecutions which can carry a 15 year term.

DISCHARGE MONITORING REPORT (DMR) - GENERAL INSTRUCTIONS

- 1. Complete this form in permanent ink or indelible pencil. The use of 'correction fluid/tape' is not allowed.**
- 2. Be sure to enter the dates for the first and last day of the period covered by the report on the form in the space marked "Monitoring Period".**
- 3. For those parameters where the "permit requirement" spaces have a requirement or limitation, provide data in the "reported" spaces in accordance with your permit.**
- 4. Enter the average and maximum quantities and units in the "reported" spaces in the columns marked "Quantity or Loading".**
KG/DAY = Concentration (mg/L) x Flow (MGD) x 3.785 G/D (Grams/Day) = Concentration (mg/L) x Flow (MGD) x 3785
- 5. Enter maximum, minimum, and/or average concentrations and units in the "reported" spaces in the columns marked "Quality or Concentration".**
- 6. For all parameters enter the number of samples which do not comply with the maximum and/or minimum permit requirements in the "reported" space in the column marked "No. Ex." (Number of Exceedances). If none, enter "0". Do NOT include monthly average violations in this field. Include any Maximum 7-Day Average and Maximum Weekly Average violations in this field. Permittees with continuous pH, or temperature monitoring requirements should consult the permit for what constitutes an exceedance and report accordingly.**
- 7. You are required to sample (at a minimum) according to the Sample Frequencies and Sample Types specified in your permit.**
- 8. Enter the actual frequency of analysis for each parameter (number of times per day, week, month, etc.) in the "reported" space in the column marked "Frequency of Analysis".**
- 9. Enter the actual type of sample (Grab, 8HC, 24HC, etc) collected for each parameter in the "reported" space in the column marked "Sample Type".**
- 10. Enter additional required data or comments in the space marked "additional permit requirements or comments". If additional required data or comments are appended to the DMR, reference appended correspondence in this field.**
- 11. Record the number of bypasses during the month, the total flow in million gallons (MG) and BOD5 in kilograms (KG) in the proper columns in the section marked "Bypasses and Overflows".**
- 12. The operator in responsible charge of the facility should review the form and sign in the space provided. If the plant is required to have a licensed operator or if the operator in responsible charge of the facility is a licensed operator, the operator's signature and certificate number must be reported in the spaces provided.**
- 13. The principal executive officer then reviews the form and must sign in the space provided and provide a telephone number where he/she can be reached. Every page of the DMR must have an original signature.**
- 14. Send the completed form(s) with original signatures to your Department of Environmental Quality Regional Office by the 10th of each month unless otherwise specified in the permit.**
- 15. You are required to retain a copy of the report for your records.**
- 16. Where violations of permit requirements are reported, attach a brief explanation in accordance with the permit requirements describing causes and corrective actions taken. Reference each separate violation by date.**
- 17. If you have any questions, contact the Department of Environmental Quality Regional Office listed on the DMR.**



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

Permit No. **VA0092533**
Effective Date: **January 29, 2010**
Expiration Date: **January 28, 2015**

AUTHORIZATION TO DISCHARGE UNDER THE VIRGINIA POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE VIRGINIA STATE WATER CONTROL LAW

In compliance with the provisions of the Clean Water Act as amended and pursuant to the State Water Control Law and regulations adopted pursuant thereto, the following owner is authorized to discharge in accordance with the information submitted with the permit application, and with this permit cover page, Part I – Effluent Limitations and Monitoring Requirements, and Part II – Conditions Applicable To All VPDES Permits, as set forth herein.

Owner Name: Klockner Pentaplast of America, Inc.
Facility Name: Klockner Pentaplast of America
County: Louisa
Facility Location: 3585 Klockner Road, Gordonsville, VA 22942

The owner is authorized to discharge to the following receiving stream:

Stream Name: South Anna River, UT
River Basin: York
River Subbasin: York
Section: 3c
Class: III
Special Standards: None

A handwritten signature in black ink, appearing to read "Thomas A. Faha", written over a horizontal line.

Thomas A. Faha
Director, Northern Regional Office
Department of Environmental Quality

01-29-10

Date

A. Effluent Limitations and Monitoring Requirements**1. Outfall 001 – Non Contact Cooling Water to South Anna, UT**

- a. There shall be no discharge of floating solids or visible foam in other than trace amounts.
- b. During the period beginning with the permit's effective date and lasting until the expiration date or the relocation of Outfall 001, whichever occurs first, the permittee is authorized to discharge from Outfall Number 001. Such discharges shall be limited and monitored by the permittee as specified below.

Parameter	Discharge Limitations				Monitoring Requirements	
	<u>Monthly Average</u> ⁽¹⁾	<u>Daily Maximum</u> ⁽¹⁾	<u>Minimum</u>	<u>Maximum</u> ⁽¹⁾	<u>Frequency</u>	<u>Sample Type</u>
Flow ⁽²⁾ (MGD)	NL	NA	NA	NL	1/3M	Estimate
pH	NA	NA	6.0 S.U.	9.0 S.U.	1/3M	Grab
Temperature (°C)	NA	32	NA	NA	1/3M	IS
Hardness (mg/L as CaCO ₃)	NL	NL	NA	NA	1/3M	Grab
Total Phosphorus (mg/L)	NL	NL	NA	NA	1/3M	Grab
Total Recoverable Copper (µg/L)*	NA	10	NA	NA	1/3M	Grab
Total Recoverable Zinc (µg/L)*	NA	90	NA	NA	1/3M	Grab

⁽¹⁾ See Part I.B.

MGD = Million gallons per day.

1/3M = Once every three months.

⁽²⁾ The maximum discharge flow is 0.0058 MGD.

N/A = Not applicable.

* See Part I.C.

NL = No limit; monitor and report.

S.U. = Standard units.

IS = Immersion Stabilization

Grab=An individual sample collected over a period of time not to exceed 15-minutes.

Estimate=Reported flow is to be based on the technical evaluation of the sources contributing to the discharge.

A. Effluent Limitations and Monitoring Requirements**2. Outfall 001 – Non Contact Cooling Water to South Anna River**

- a. There shall be no discharge of floating solids or visible foam in other than trace amounts.
- b. During the period beginning with the discharge to the new outfall 001 and lasting until the permit's expiration date, the permittee is authorized to discharge from Outfall Number 001. Such discharges shall be limited and monitored by the permittee as specified below.

Parameter	Discharge Limitations				Monitoring Requirements	
	<u>Monthly Average</u> ⁽¹⁾	<u>Daily Maximum</u> ⁽¹⁾	<u>Minimum</u>	<u>Maximum</u> ⁽¹⁾	<u>Frequency</u>	<u>Sample Type</u>
Flow ⁽²⁾ (MGD)	NL	NA	NA	NL	1/3M	Estimate
pH	NA	NA	6.0 S.U.	9.0 S.U.	1/3M	Grab
Temperature (°C)	NA	32	NA	NA	1/3M	IS
Hardness (mg/L as CaCO ₃)	NL	NL	NA	NA	1/3M	Grab
Total Phosphorus (mg/L)	NL	NL	NA	NA	1/3M	Grab
Total Recoverable Copper (µg/L)*	NA	14	NA	NA	1/3M	Grab
Total Recoverable Zinc (µg/L)*	NA	130	NA	NA	1/3M	Grab

⁽¹⁾ See Part I.B.

MGD = Million gallons per day.

1/3M = Once every three months.

⁽²⁾ The maximum discharge flow is 0.0058 MGD.

N/A = Not applicable.

* See Part I.C.

NL = No limit; monitor and report.

S.U. = Standard units.

IS = Immersion Stabilization

Grab = An individual sample collected over a period of time not to exceed 15-minutes.

Estimate = Reported flow is to be based on the technical evaluation of the sources contributing to the discharge.

B. Additional Monitoring Requirements, Quantification Levels and Compliance Reporting

1. Quantification Levels

- a. Maximum quantification levels (QLs) shall be as follows:

<u>Characteristic</u>	<u>Quantification Level</u>
Copper	5 µg/L
Zinc	20 µg/L

- b. The permittee may use any approved method, which has a QL equal to or lower than the QL listed in B.1.a. above. The QL is defined as the lowest concentration used to calibrate a measurement system in accordance with the procedures published for the method.
- c. It is the responsibility of the permittee to ensure that proper quality assurance/quality control (QA/QC) protocols are followed during the sampling and analytical procedures. QA/QC information shall be documented to confirm that appropriate analytical procedures have been used and the required QLs have been attained.
- d. An appropriate analytical method for metals shall be selected from the following list of EPA methods, or any approved method in 40 CFR Part 136, which will achieve a QL that is less than or equal to the QL specified in B.1.a. above.

Metal	Analytical Methods
Copper	1638; 1640
Zinc	1638; 1639

2. Compliance Reporting for parameters in Part I.A.

- a. Monthly Average – Compliance with the monthly average limitations and/or reporting requirements for the parameters listed in Part I. A shall be determined as follows: All concentration data below the QL listed above shall be treated as zero. All concentration data equal to or above the QL listed in a. above shall be treated as it is reported. An arithmetic average shall be calculated using all reported data, including the defined zeros, for the month. This arithmetic average shall be reported on the DMR as calculated. If all data are below the QL then the average shall be reported as <QL. If reporting for quantity is required on the DMR and the calculated concentration is <QL then report <QL for the quantity, otherwise use the calculated concentration to determine the monthly average quantity.
- b. Daily Maximum - Compliance with the daily maximum limitations and/or reporting requirements for the parameters listed in Part I.A. shall be determined as follows: All concentration data below the QL listed above shall be treated as zero. All concentration data equal to or above the QL listed in a. above shall be treated as reported. An arithmetic average of the values shall be calculated using all reported data, including defined zeros, collected for each day during the reporting month. The maximum value of these daily averages thus determined shall be reported on the DMR as the Daily Maximum. If all data are below the QL then the average shall be reported as <QL. If reporting for quantity is required on the DMR and the calculated concentration is <QL then report <QL for the quantity otherwise use the calculated concentration to determine the quantity.

- c. Any single datum required shall be reported as <QL if it is less than the QL in a. above. Otherwise the numerical value shall be reported.
- d. The permittee shall report at least the same number of significant digits as the permit limit for a given parameter. Regardless of the rounding convention used (i.e., 5 always rounding up or to the nearest even number) by the permittee, the permittee shall use the convention consistently, and shall ensure that consulting laboratories employed by the permittee use the same convention.

C. Schedule of Compliance

1. The permittee shall achieve compliance with the final limits specified in Part I.A of this permit for copper and zinc in accordance with the following schedule:

ACTION	TIME FRAME
a. Submit a plan to achieve compliance with final copper and zinc limits.	A plan shall be submitted 90 days from the effective date of the permit.
b. Report biannually of progress on attainment of final copper and zinc limits.	By August 1, 2010, February 1, 2011, August 1, 2011, February 1, 2012, August 1, 2012, February 1, 2013, August 1, 2013, and February 1, 2014.
c. Achieve compliance with final copper and zinc limits.	Within 60 days of the completion of the compliance plan activities and implementation of the corrective measure(s) but no later than four (4) years from the effective date of the permit.

2. No later than 14 calendar days following a date identified in the above schedule of compliance, the permittee shall submit to the DEQ - Northern Regional Office, either a report of progress or, in the case of specific actions being required by identified dates, a written notice of compliance or noncompliance. In the latter case, the notice shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next schedule requirement.
3. During the compliance period, the permittee must (1) continue to operate the facility in a manner that will minimize or avoid degradation of the effluent from current operating levels and (2) notify DEQ prior to making any substantial process control modifications that might degrade the quality of the effluent.

D. Other Requirements and Special Conditions

1. Discharge Locations

Should the facility relocate Outfall 001 to directly discharge to the South Anna River, the non contact cooling water discharge to the South Anna, UT shall cease and all non contact cooling water discharges shall be directly to the South Anna River through the new Outfall 001.

2. Materials Handling/Storage

Any and all product, materials, industrial wastes, and/or other wastes resulting from the purchase, sale, mining, extraction, transport, preparation, and/or storage of raw or intermediate materials, final product, by-product or wastes, shall be handled, disposed of, and/or stored in such a manner so as not to permit a discharge of such product, materials, industrial wastes, and/or other wastes to State waters, except as expressly authorized.

3. Operation and Maintenance (O&M) Manual Requirement

The permittee shall develop an Operations and Maintenance (O&M) Manual for the treatment works. This manual shall detail the practices and procedures, which will be followed to ensure compliance with the requirements of this permit. The manual shall be submitted to the DEQ-Northern Regional Office for approval by April 29, 2010. The permittee shall operate the treatment works in accordance with the approved O&M Manual. This manual shall include, but not necessarily be limited to, the following items, as appropriate:

- a. Treatment system design, treatment system operation, routine preventative maintenance of units within the treatment system, critical spare parts inventory and record keeping;
- b. Techniques to be employed in the collection, preservation and analysis of effluent samples (and sludge samples if sludge analyses are required);
- c. Procedures for handling, storing, and disposing of all wastes, fluids, and pollutants that will prevent these materials from reaching state waters;
- d. A plan for the management and/or disposal of waste solids, residues, Residue/Sludge Management and Disposal Plan;
- e. Discussion of Best Management Practices, if applicable; and
- f. Procedures for measuring and recording the duration and volume of treated wastewater discharged.

Any changes in the practices and procedures followed by the permittee shall be documented and submitted for staff approval within 90 days of the effective date of the changes. Upon approval of the submitted manual changes, the revised manual becomes an enforceable part of the permit. Noncompliance with the O&M Manual shall be deemed a violation of the permit.

4. Water Quality Criteria Reopener

Should effluent monitoring indicate the need for any water quality-based limitations, this permit may be modified or alternatively revoked and reissued to incorporate appropriate limitations.

5. Notification Levels

The permittee shall notify the Department as soon as they know or have reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following notification levels:
 - (1) One hundred micrograms per liter;
 - (2) Two hundred micrograms per liter for acrolein and acrylonitrile; five hundred micrograms per liter for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter for antimony;
 - (3) Five times the maximum concentration value reported for that pollutant in the permit application; or
 - (4) The level established by the Board.

b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant, which is not limited in this permit, if that discharge will exceed the highest of the following notification levels:

- (1) Five hundred micrograms per liter;
- (2) One milligram per liter for antimony;
- (3) Ten times the maximum concentration value reported for that pollutant in the permit application; or
- (4) The level established by the Board.

6. Nutrient Reopener

This permit may be modified or alternatively revoked and reissued to include new or alternative nutrient limitations and/or monitoring requirements should the Board adopt nutrient standards for the waterbody receiving the discharge or if a future water quality regulation or statute requires new or alternative nutrient control

7. Cooling Water Systems

The permittee shall at all times properly operate and maintain all cooling water systems. Inspections shall be conducted for each cooling water unit by the plant personnel at least once per year with reports maintained on site.

8. Cooling Tower Additives

The use of any chemical additives not identified in the registration statement without prior approval of the DEQ is prohibited. Prior approval shall be obtained from the DEQ before any changes are made to the chemical and/or non-chemical treatment technology employed in the cooling water system. Requests for approval of the change shall be made in writing and include the following information:

- a. Describe the chemical and/or non-chemical treatment to be employed and its purpose; if chemical additives are used, provide the information prescribed in subdivisions 8 b, c, d and e;
- b. Provide name and manufacturer of each additive used;
- c. Provide list of active ingredients and percentage composition;
- d. Give the proposed schedule and quantity of chemical usage, and estimate the concentration in the discharge;
- e. Attach available aquatic toxicity information for each additive proposed for use; and
- f. Attach any other information such as product or constituent degradation, fate, transport, synergies, bioavailability, etc. that will aid the board with the toxicity evaluation for the discharge.

9. Total Maximum Daily Load (TMDL) Reopener

This permit shall be modified or alternatively revoked and reissued if any approved wasteload allocation procedure, pursuant to Section 303(d) of the Clean Water Act, imposes wasteload allocations, limits or conditions on the facility that are not consistent with the permit requirements.

CONDITIONS APPLICABLE TO ALL VPDES PERMITS

A. Monitoring

1. Samples and measurements taken as required by this permit shall be representative of the monitored activity.
2. Monitoring shall be conducted according to procedures approved under Title 40 Code of Federal Regulations Part 136 or alternative methods approved by the U.S. Environmental Protection Agency, unless other procedures have been specified in this permit.
3. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals that will insure accuracy of measurements.

B. Records

1. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The individual(s) who performed the sampling or measurements;
 - c. The date(s) and time(s) analyses were performed;
 - d. The individual(s) who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
2. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years, the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period of retention shall be extended automatically during the course of any unresolved litigation regarding the regulated activity or regarding control standards applicable to the permittee, or as requested by the Board.

C. Reporting Monitoring Results

1. The permittee shall submit the results of the monitoring required by this permit not later than the 10th day of the month after monitoring takes place, unless another reporting schedule is specified elsewhere in this permit. Monitoring results shall be submitted to:

Department of Environmental Quality - Northern Regional Office (DEQ-NRO)
13901 Crown Court
Woodbridge, VA 22193

Monitoring results shall be reported on a Discharge Monitoring Report (DMR) or on forms provided, approved or specified by the Department.

2. If the permittee monitors any pollutant specifically addressed by this permit more frequently than required by this permit using test procedures approved under Title 40 of the Code of Federal Regulations Part 136 or using other test procedures approved by the U.S. Environmental Protection Agency or using procedures specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or reporting form specified by the Department.

3. Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.

D. Duty to Provide Information.

The permittee shall furnish to the Department, within a reasonable time, any information which the Board may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Board may require the permittee to furnish, upon request, such plans, specifications, and other pertinent information as may be necessary to determine the effect of the wastes from this discharge on the quality of state waters, or such other information as may be necessary to accomplish the purposes of the State Water Control Law. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.

E. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

F. Unauthorized Discharges

Except in compliance with this permit, or another permit issued by the Board, it shall be unlawful for any person to:

1. Discharge into state waters sewage, industrial wastes, other wastes, or any noxious or deleterious substances; or
2. Otherwise alter the physical, chemical or biological properties of such state waters and make them detrimental to the public health, or to animal or aquatic life, or to the use of such waters for domestic or industrial consumption, or for recreation, or for other uses.

G. Reports of Unauthorized Discharges.

Any permittee who discharges or causes or allows a discharge of sewage, industrial waste, other wastes or any noxious or deleterious substance into or upon state waters in violation of Part II.F.; or who discharges or causes or allows a discharge that may reasonably be expected to enter state waters in violation of Part II.F., shall notify the Department of the discharge immediately upon discovery of the discharge, but in no case later than 24 hours after said discovery. A written report of the unauthorized discharge shall be submitted to the Department, within five days of discovery of the discharge. The written report shall contain:

1. A description of the nature and location of the discharge;
2. The cause of the discharge;
3. The date on which the discharge occurred;
4. The length of time that the discharge continued;
5. The volume of the discharge;
6. If the discharge is continuing, how long it is expected to continue;
7. If the discharge is continuing, what the expected total volume of the discharge will be; and
8. Any steps planned or taken to reduce, eliminate and prevent a recurrence of the present discharge or any future discharges not authorized by this permit.

Discharges reportable to the Department under the immediate reporting requirements of other regulations are exempted from this requirement.

H. Reports of Unusual or Extraordinary Discharges.

If any unusual or extraordinary discharge including a bypass or upset should occur from a treatment works and the discharge enters or could be expected to enter state waters, the permittee shall promptly notify, in no case later than 24 hours, the Department by telephone after the discovery of the discharge. This notification shall provide all available details of the incident, including any adverse affects on aquatic life and the known number of fish killed. The permittee shall reduce the report to writing and shall submit it to the Department within five days of discovery of the discharge in accordance with Part II.I.2. Unusual and extraordinary discharges include but are not limited to any discharge resulting from:

1. Unusual spillage of materials resulting directly or indirectly from processing operations;
2. Breakdown of processing or accessory equipment;
3. Failure or taking out of service some or all of the treatment works; and
4. Flooding or other acts of nature.

I. Reports of Noncompliance

The permittee shall report any noncompliance which may adversely affect state waters or may endanger public health.

1. An oral report shall be provided within 24 hours from the time the permittee becomes aware of the circumstances. The following shall be included as information which shall be reported within 24 hours under this paragraph:
 - a. Any unanticipated bypass; and
 - b. Any upset which causes a discharge to surface waters.
2. A written report shall be submitted within 5 days and shall contain:
 - a. A description of the noncompliance and its cause;
 - b. The period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
 - c. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

The Board may waive the written report on a case-by-case basis for reports of noncompliance under Part II.I. if the oral report has been received within 24 hours and no adverse impact on state waters has been reported.

3. The permittee shall report all instances of noncompliance not reported under Parts II, I.1. or I.2., in writing, at the time the next monitoring reports are submitted. The reports shall contain the information listed in Part II.I.2.

NOTE: The immediate (within 24 hours) reports required in Parts II, G., H. and I. may be made to the Department's Northern Regional Office at (703) 583-3800 (voice) or (703) 583-3821 (fax). For reports outside normal working hours, leave a message and this shall fulfill the immediate reporting requirement. For emergencies, the Virginia Department of Emergency Services maintains a 24-hour telephone service at 1-800-468-8892.

J. Notice of Planned Changes.

1. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - a. The permittee plans alteration or addition to any building, structure, facility, or installation from which there is or may be a discharge of pollutants, the construction of which commenced:
 - 1) After promulgation of standards of performance under Section 306 of Clean Water Act which are applicable to such source; or
 - 2) After proposal of standards of performance in accordance with Section 306 of Clean Water Act which are applicable to such source, but only if the standards are promulgated in accordance with Section 306 within 120 days of their proposal;
 - b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations nor to notification requirements specified elsewhere in this permit; or
 - c. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
2. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

K. Signatory Requirements.

1. All permit applications shall be signed as follows:
 - a. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - 1) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or
 - 2) The manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second-quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures;
 - b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
 - c. For a municipality, state, federal, or other public agency: by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a public agency includes:
 - 1) The chief executive officer of the agency, or
 - 2) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.

2. All reports required by permits, and other information requested by the Board shall be signed by a person described in Part II.K.1., or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Part II.K.1.;
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.); and
 - c. The written authorization is submitted to the Department.
3. Changes to authorization. If an authorization under Part II.K.2. is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part II.K.2. shall be submitted to the Department prior to or together with any reports, or information to be signed by an authorized representative.
4. Certification. Any person signing a document under Parts II, K.1. or K.2. shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

L. Duty to Comply.

The permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the State Water Control Law and the Clean Water Act, except that noncompliance with certain provisions of this permit may constitute a violation of the State Water Control Law but not the Clean Water Act. Permit noncompliance is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if this permit has not yet been modified to incorporate the requirement.

M. Duty to Reapply.

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee shall apply for and obtain a new permit. All permittees with a currently effective permit shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Board. The Board shall not grant permission for applications to be submitted later than the expiration date of the existing permit.

N. Effect of a Permit.

This permit does not convey any property rights in either real or personal property or any exclusive privileges, nor does it authorize any injury to private property or invasion of personal rights, or any infringement of federal, state or local law or regulations.

O. State Law.

Nothing in this permit shall be construed to preclude the institution of any legal action under, or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any other state law or regulation or under authority preserved by Section 510 of the Clean Water Act. Except as provided in permit conditions on "bypassing" (Part II.U.), and "upset" (Part II.V.) nothing in this permit shall be construed to relieve the permittee from civil and criminal penalties for noncompliance.

P. Oil and Hazardous Substance Liability.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Sections 62.1-44.34:14 through 62.1-44.34:23 of the State Water Control Law.

Q. Proper Operation and Maintenance.

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes effective plant performance, adequate funding, adequate staffing, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

R. Disposal of solids or sludges.

Solids, sludges or other pollutants removed in the course of treatment or management of pollutants shall be disposed of in a manner so as to prevent any pollutant from such materials from entering state waters.

S. Duty to Mitigate.

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

T. Need to Halt or Reduce Activity not a Defense.

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

U. Bypass.

1. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts II, U.2. and U.3.
2. Notice
 - a. Anticipated bypass. If the permittee knows in advance of the need for a bypass, prior notice shall be submitted, if possible at least ten days before the date of the bypass.
 - b. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part II.I.
3. Prohibition of bypass.
 - a. Bypass is prohibited, and the Board may take enforcement action against a permittee for bypass, unless:
 - 1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - 2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - 3) The permittee submitted notices as required under Part II.U.2.
 - b. The Board may approve an anticipated bypass, after considering its adverse effects, if the Board determines that it will meet the three conditions listed above in Part II.U.3.a.

V. Upset.

1. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of Part II.V.2. are met. A determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is not a final administrative action subject to judicial review.
2. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - b. The permitted facility was at the time being properly operated;
 - c. The permittee submitted notice of the upset as required in Part II.I.; and
 - d. The permittee complied with any remedial measures required under Part II.S.
3. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

W. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act and the State Water Control Law, any substances or parameters at any location.

For purposes of this section, the time for inspection shall be deemed reasonable during regular business hours, and whenever the facility is discharging. Nothing contained herein shall make an inspection unreasonable during an emergency.

X. Permit Actions.

Permits may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Y. Transfer of permits

1. Permits are not transferable to any person except after notice to the Department. Except as provided in Part II.Y.2., a permit may be transferred by the permittee to a new owner or operator only if the permit has been modified or revoked and reissued, or a minor modification made, to identify the new permittee and incorporate such other requirements as may be necessary under the State Water Control Law and the Clean Water Act.
2. As an alternative to transfers under Part II.Y.1., this permit may be automatically transferred to a new permittee if:
 - a. The current permittee notifies the Department at least 30 days in advance of the proposed transfer of the title to the facility or property;
 - b. The notice includes a written agreement between the existing and new permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them; and
 - c. The Board does not notify the existing permittee and the proposed new permittee of its intent to modify or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in Part II.Y.2.b.

Z. Severability

The provisions of this permit are severable, and if any provision of this permit or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.